



# MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

## TEST - REPORT

Not for legal use

Ref. No. & Date :- No. GGMSSS/20B/2024/530 dated 20.07.2024  
Issued to :-  The Principal,  
:- Govt. Girls Sr. Sec. School,  
:- Sector - 20 - B, Chandigarh.  
Quantity of sample :- Approximate 1200 ml.  
Date of Collection :- 27-07-2024  
Client reference :- Sample Collected by Laboratory Staff  
Packing of sample :- Sample filled in P.P. and Glass Bottle  
Source of sample :- from School tap of Govt. Girls Sr. Sec School  
Sector - 20 - B, Chandigarh.


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.75
2	Odour	Agreeable	-----	Agreeable
3	Taste	Agreeable	-----	Agreeable
4	Turbidity	< 1.0	mg/l	0.9
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO <sub>3</sub> )	< 200	mg/l	80
7	Total Hardness (as CaCO <sub>3</sub> )	< 200	mg/l	72
8	Chloride (as Cl)	< 250	mg/l	04
9	Free & Saline Ammonia	Nil	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	114
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.07/2024-25/204237, dated 26.07.2024, Amount Rs.3300/-

**Note:- Water is fit for drinking**

Lab No.- MCPHL/24/.....3199.....

Dated:- 29.07.2024


  
Chemist  
M.C.P.H. Laboratory  
Chandigarh


  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh  
Dated :- 29.07.2024

Endst No. MCPH/24/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh

For information Please.

  
Chemist  
M.C.P.H. Laboratory  
Chandigarh

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh